



ADDENDUM #2

CITY OF BROOKHAVEN 18-174 For Lynwood Recreation Center Generator

1. Which panel is the generator going to feed? What is the amperage? Single or 3-phase?
Backing up the 200 amp, 240 volt, single phase panel in the rec center.
2. Is the referenced Generac model number supposed to be SG050 rather than SG505? **The model # should be SG050.**
3. Does the generator require a sound attenuation housing? If so, what sound level (dBA at meters)? **A standard weather enclosure with no additional sound attenuation.**
4. What size battery charger is required (amps)? **10 amp, 120 volt battery charger.**
5. Is this an NFPA 110 application? **The unit does meet the NFPA 110 requirements.**
6. Do you require an onsite load bank test? If so, how many hours? **(4) hour load bank test on the initial start-up.**
7. What is the required warranty period? **(1) year labor and (2) year parts warranty**
8. Is a 200A generator mounted breaker required? **It is required.**