



Invitation To Bid (ITB)

ITB 19-401

ST-09 Ashford Dunwoody/Johnson Ferry Intersection Improvements

ADDENDUM #1 – Q & A

Question #1:

The excavation line to construct the proposed swale is within two feet of the trunk of some of the trees. How close to the trunk of a tree will the City require a Contractor to excavate?

Or is the City expecting to remove all trees within the right of way?

Answer:

Trees within the construction limits have to be removed.

*** * * END OF ADDENDUM * * ***