



**DATE: January 29, 2021**

**TO: All Offerors'**

**FROM: City of Brookhaven Purchasing Department**

**RE: ITB No. 21-102, Murphey Candler Park Nature Trail**

Please see Addendum No. 2 for the above-referenced solicitation.



1. The following change has been made to the above-referenced solicitation.

**Additional/Updated Questions and Answers**

2. All other terms and conditions remain the same.

**ADDENDUM NO. 2**  
**Invitation to Bid, No. 21-102**  
**Murphey Candler Park Nature Trail**  
**REVISED 1/29/2021**

A. The following are additional and updated questions received and City of Brookhaven responses for the above- referenced solicitation:

1. Will the city accept bridge alternates such as Pioneer or Contech?  
**No. Bridge Brothers will be the sole supplier for the bridge listed for this project. No alternate manufactures will be allowed.**
2. The scale on the grading sheet isn't correct, will it be corrected?  
**The scale on the drawing is off by a factor of 2.**
3. Does the entire boardwalk require aluminum handrails, or only at certain locations? If it is only for a certain location, please provide the locations for the aluminum handrail.  
**Please bid the length of the handrail to be installed on all elevations above 2 feet. Bid project with railing per detail #5 on sheet C-220.**
4. Can you provide a helical pier quantity for Permatrak?  
**The contractor is responsible for determining the quantity with their pier provider.**
5. On sheet C-300, note "existing drainage channels to remain", the elevations of the boardwalk (TB) change from 870.50 to 896.5 within only 20 LF of length. Please confirm.  
**The point called out as 867.58 ex and 896.50 TB should be corrected to 870.00 TB.**
1. Will the contractor get paid for additional depth of helical piers?  
**Yes.**
2. How do contractors bid if the design has not been completed?  
**The designs are complete.**
3. If the entire boardwalk gets aluminum handrail, where does the Permatrak curb get installed?  
**The Permatrak curb would be installed along the boardwalk where elevations are less than 2 feet.**
4. TB Elevations-Do these elevations meet the Brookhaven ADA Requirements as stated in General Note 5 on Sheet C-201?  
**Yes.**
5. Where is the additional lay down area referenced?  
**It's referenced east of the add alternate location on the drawing.**
6. Please elaborate on what inspections are done by the contractor at the contractors' cost.  
**The contractor is responsible for all of the inspections related to the project.**